

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1 3
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 02-Jul-2004	4. REQUISITION/PURCHASE REQ. NO. W38XDD-4033-8518		5. PROJECT NO.(If applicable)
6. ISSUED BY US ARMY CORPS OF ENG.-NASHVILLE- W912P5 CELRN-CT, ROOM A604 110 NINTH AVE. SOUTH P O BOX 1070 NASHVILLE TN 37202-1070	CODE W912P5	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. W912P5-04-R-0013	
		X	9B. DATED (SEE ITEM 11) 24-May-2004	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) SEE CONTINUATION SHEET				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED 01-Jul-2004	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMENDMENT 0002

The following clarifications and changes are made to the original Solicitation for this project:

1. It is the Corps intention to exercise the option so that both units can be rewound back-to-back. Only one mob/demob will be required for the entire job.
2. The re-grouting is hereby deleted from the contract scope of work. Therefore, lifting of the frame will not be required. The following portions of the specs shall be deleted in their entirety:
 - o Section 01330, Submittal Register, page 6 of 6, delete “Stator Frame Support Pad Grout Removal/Replacement Procedure.”
 - o Section 16210, page 16210-i, delete item number 2.8 “New Grout for the Stator Frame Sole Plate Area.”
 - o Section 16210, delete paragraph 1.3.42 “Stator Frame Support Pad Procedure.”
 - o Section 16210, delete paragraph 2.8 “New Grout for the Stator Frame Sole Plate Area.”
 - o Section 16210, delete paragraph 3.9.2 “Stator Frame Removal and Sole Plate Grout Removal and Replacement.”
3. USACE will provide any necessary project personal at no cost to the contractor for approved work periods outside the normal duty hours. This work must be approved in advance.
4. It is intended that the contractor remove and replace all key bars (i.e. dovetails) as part of the new core. Any approved method of installation will be acceptable.
5. Section 01330, Submittal Register, PG 6 of 6, delete “Stator Frame Support Pad Grout Removal/Replacement Procedure.”
6. Section 16210, page 16210-i, item 2.8, delete “New Grout for the Stator Frame Sole Plate Area”, in its entirety and insert “NOT USED.”
7. Section 16210, delete paragraph 1.3.42 “Stator Frame Support Pad Procedure”, in its entirety.
8. Section 16210, delete paragraph 2.8 “New Grout for the Stator Frame Sole Plate Area ”, in its entirety.
9. Section 16210, delete paragraph 3.9.2 “Stator Frame Removal and Sole Plate Grout Removal and Replacement”, in its entirety.
10. Section 16210, paragraph 3.9.1 “Unstack Stator Core”, add new sentence to end of paragraph as follows: “All keybars (dovetails) shall be removed.”
11. Section 16210, paragraph 3.9.4 “Center and Round Stator”, revise third sentence to read as follows: “This will involve complete removal of the keybars (dovetails) and welding new keybars (dovetails) in the proper locations.”
12. Section 16210, paragraph 3.9.5 “Restack Stator Iron”, revise the first sentence as follows: “After installation of new keybars (dovetails), the stator shall be restacked without splits using all new laminations and vent duct spacers.”

-----LAST ITEM-----

SECTION 00010 - SOLICITATION CONTRACT FORM

The Issued By organization has changed from

US ARMY CORPS OF ENGINEERS-CELRN/CT
FEDERAL OFFICE BLDG-ROOM A604
P O BOX 1070
110 9TH AVENUE SOUTH
NASHVILLE TN 37202-1070

to

US ARMY CORPS OF ENG.-NASHVILLE- W912P5
CELRN-CT, ROOM A604
110 NINTH AVE. SOUTH
P O BOX 1070
NASHVILLE TN 37202-1070

(End of Summary of Changes)